



Our Ref: ES G2017-26499/A22183361
Enquiries: Tony Smith
Telephone: 08 6251 1960

Mr W Ferreira
Esperance Gas Distribution Company Pty Ltd
Office 22B Dutton Arcade
91 Dempster Street
ESPERANCE WA 6450

Dear Mr Ferreira

EXEMPTION FROM THE REQUIREMENT TO ATTACH AN APPROVAL BADGE OR LABEL UNDER SPECIFIED CONDITIONS.

Regulation 28 of the Gas Standards (Gasfitting and Consumer Gas Installations) Regulations 1999 (the Regulations) requires a registered gasfitter to attach an approved badge or label in an approved place on completion of the gasfitting work.

Subregulation 28 (6) provides for the Director of Energy Safety (the Director) to exempt a registered gasfitter from this requirement in a particular case or class of case.

The Director has determined that subregulation (2) and (3) do not apply if:

- an eNotice is submitted; and
- the gas installation, domestic or commercial, is supplied with natural gas.

For clarity, an approved badge is still required to be attached in accordance with subregulation (2) to an installation in the following cases:

- if a paper based Notice of Completion is submitted
- all LP Gas installations domestic, commercial and industrial installations
- all Industrial natural gas installations
- marine craft
- caravans
- mobile catering installations
- LP Gas, Forklift ,CNG, LNG - mobile vehicle installations

If you have any queries in relation to this matter, please contact Tony Smith on 08 6251 1960 or by email at anthony.smith@dmirs.wa.gov.au.

Yours sincerely

David Allan
DIRECTOR OF ENERGY SAFETY
or Delegate
9 April 2018